

**Wallingford Fire Prevention Bureau**  
75 Masonic Avenue  
Wallingford, CT 06492  
Phone: (203) 294-2766  
Fax: (203) 294-2736  
[www.town.wallingford.ct.us](http://www.town.wallingford.ct.us)

## **Guide For Fire Marshal's Office Final Inspection**

**Below is a partial list of items required to be completed prior to approval for C/O**

- Exiting Systems must be clear and unobstructed. Proper hardware shall be installed on all exit doors. Dead bolts, slide bolts, bars, or other similar securing devices are not permitted.
- Exit signs and emergency lighting must function properly. Exit and Emergency lights shall be tied to the local lighting circuit.
- Fire Extinguishers, including those newly purchased, must be inspected, properly mounted and tagged.
- Premise address must be on each building unit, with number no less than 3" (inches) in height and visible from the street.
- Fire Alarm System (where applicable) shall be tested with documentation provided to the Fire Marshal's Office.
- All Fire Sprinkler/Suppression Systems (where applicable) shall be tested with documentation provided to the Fire Marshal's Office.
- Fire Department Connection (FDC) must be tested with documentation provided to the Fire Marshal's Office. FDC must be marked and unobstructed, including vegetation, parking spaces, etc with caps in place.
- Where a fire department Knox Box is installed or required, master key/keys must be available along with emergency contact information.

**The items above are general in nature and may not address all situations. For further information please contact the Wallingford Fire Prevention Bureau.**