

Wallingford Fire Prevention Bureau
75 Masonic Avenue
Wallingford, CT 06492
Phone: (203) 294-2766
Fax: (203) 294-2736
www.town.wallingford.ct.us

Guide For Fire Marshal's Office Final Inspection

Below is a partial list of items required to be completed prior to approval for C/O

- Exiting Systems must be clear and unobstructed. Proper hardware shall be installed on all exit doors. Dead bolts, slide bolts, bars, or other similar securing devices are not permitted.
- Exit signs and emergency lighting must function properly. Exit and Emergency lights shall be tied to the local lighting circuit.
- Fire Extinguishers, including those newly purchased, must be inspected, properly mounted and tagged.
- Premise address must be on each building unit, with number no less than 3" (inches) in height and visible from the street.
- Fire Alarm System (where applicable) shall be tested with documentation provided to the Fire Marshal's Office.
- All Fire Sprinkler/Suppression Systems (where applicable) shall be tested with documentation provided to the Fire Marshal's Office.
- Fire Department Connection (FDC) must be tested with documentation provided to the Fire Marshal's Office. FDC must be marked and unobstructed, including vegetation, parking spaces, etc with caps in place.
- Where a fire department Knox Box is installed or required, master key/keys must be available along with emergency contact information.

The items above are general in nature and may not address all situations. For further information please contact the Wallingford Fire Prevention Bureau.